

To: Cohen, Amy[Cohen.Amy@epa.gov]
Cc: John Wren[jwren@mountaire.com]
From: Beth Sise
Sent: Thur 12/7/2017 2:24:51 PM
Subject: FW: Herbert Ln
HERBERT LN. WORKORDER 30NOV17.PDF

Good morning Amy,

Here is the work that was completed by Sharp Water last week for the point of entry systems on Herbert Lane, fyi. Note email below.

Let me know if need anything else.

Thanks

Beth

Beth B. Sise

Environmental Mgr.

Mountaire Farms of Delaware, Inc.

29292 John J. Williams Hwy.

Millsboro DE 19966



302-934-3094 (ph)

302-934-3081 (fax)

From: **Ex. 6 - Personal Privacy**

Sent: Friday, December 01, 2017 9:25 AM

To: John Wren <jwren@mountaire.com>

Cc: **Ex. 6 - Personal Privacy**

Beth Sise <bsise@mountaire.com>

Subject: Herbert Ln

ATTACHMENT NOTICE

This email was sent from outside of Mountaire and contains at least one attachment.

Do not open hyperlinks or attachments if you are not familiar with the sender of the message. If the email is from a known sender but appears suspicious, contact the sender to verify that they sent the message before opening any attachments.

If you have any questions, please contact the IT Helpdesk at 302-934-3000 or helpdesk@mountaire.com

Note: This advisory was automatically prepended to your email by Mountaire's Exchange server.

Mr. Wren,

Attached are copies of the work orders from yesterday's service for the residents of Herbert Ln. All received a cook/cold cooler with 20 gals of water with the exception of **Ex. 6 - Personal Privacy** who requested 4 3gal bottles due to the weight. Mechanically all units are working properly & received a citric acid cleaning of the media bed. **Ex. 6 - Personal Privacy** was passing 4 Nitrates & **Ex. 6 - Personal Privacy** was passing 8 Nitrates. **Ex. 6 - Personal Privacy** told me her original water test was over 25 Nitrates. I retested the water at her request & the results are the same, at 8 Nitrates. As noted on the workorder, the time of day was off by 14 hours. This would engage a recharge at 1p.m. vs. the standard of 2 a.m. If the water sample was collected between the hours of 1 & 3 p.m., on the scheduled recharge day, the water collected would not be treated. The reason being is that, during a recharge the water softener is bypassed internally, & any water used will go around the unit vs. through the unit. This is merely speculation, as I do not know when the sample was collected, but if this is the case a reading of 25 Nitrates is not surprising. We are working diligently to prep. the water coolers for the remaining residents to be delivered, Monday. Thank You,

Ex. 6 - Personal Privacy

Ex. 6 - Personal Privacy

Sharp Water Culligan

Ex. 6 - Personal Privacy